

June 1, 2013

2013 Annual Drinking Water Quality Report

Stevensville Water System

Stevensville Treatment Facility - 208 Church Street

Business Park Facility - 230 Bateau Drive

Thompson Creek Facility - 610 Marion Quimby Drive

Bayside Marina Facility – 103 Tackle Circle

Queens Landing Facility – 131 Queens Landing Drive

Bridgepointe Facility – 9025 Bridgepointe Drive

Kent Island Village Facility – 1839 Anchorage Drive

MDE Public Water System ID No. 170019

This report is required by the federal Safe Water Drinking Act Amendment of 1996 and is designed to educate you about the quality of the water we deliver to you every day. We are pleased to inform you that your drinking water is safe and meets all federal and state requirements. **However we are aware that we still have iron issues (brown water) occasionally that can be a significant inconvenience, but is not a health issue.** Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

The Sanitary District routinely monitors for constituents in your drinking water according to Federal and State laws. With the interconnection of the Stevensville and Chester water distribution systems, your water can now be supplied by seven water treatment facilities. The Stevensville water treatment facility is the primary producer and utilizes groundwater from a 20-inch well 1590 feet deep into the Lower Patapsco aquifer. The second treatment plant is the Business Park water treatment facility which utilizes groundwater from a new single 12 inch well 1494 feet deep into the Lower Patapsco aquifer. The third treatment plant is the Thompson Creek water treatment facility which was utilizing groundwater from a single 6-inch well 240 feet deep into the Aquia, however this facility is currently off-line due to withdrawal limits placed by the State's permit. The fourth plant is the Bayside facility which utilizes two 10-inch wells 670 feet into the Magothy aquifer. The fifth plant is the Queen's Landing water treatment facility, which utilizes two 10 inch wells 280 feet deep into the Aquia. The sixth plant is the Bridgepointe water facility, which utilizes groundwater from two 6-inch wells 710 feet deep into the Magothy aquifer. The final being the Kent Island Village water treatment facility, which utilizes a single 6 inch well 290 feet deep into the Aquia.

The enclosed table indicates the results of our monitoring for the period of January 1 to December 31, 2012. All drinking water, including bottled drinking water, may be reasonably expected to contain at least a small amount of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Sanitary District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking and cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the EPA Safe Drinking Water Hotlines at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>.

(Please note EPA mandates the previous two paragraphs. Cryptosporidium is a microbe found in some surface water supplies such as rivers or reservoirs. It is not typically found in groundwater, which is where all of our water supplies originate. In regards to lead, none of our water systems have ever had lead issues.)

In the following table you will find many terms and abbreviations you might not be familiar with. To help you to better understand these terms we've provided the following definitions:

Non-Detect - laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) - one part per million corresponds to one minute in two years or a single penny in \$10,000. Also equivalent to milligrams per liter (mg/l).

Parts per billion (ppb) - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000. Also equivalent to micrograms per liter ($\mu\text{g/l}$).

Action Level (AL) - the concentration of a contaminant, which, if exceeded, triggers treatment or other requirements that a water system must follow.

Maximum Contaminant Level Goal (MCLG) - The 'Goal' is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Contaminant Level (MCL) - The 'Maximum Allowed' is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

The Sanitary District's water staff consists of nine personnel with a combined experience of 50 years. Each operator is required to obtain 30 hours of formal training every 3 years in water treatment and water distribution operations.

Major decisions affecting the water utility are made by the County Commissioners, sitting as the Sanitary Commission. Should you wish to attend, the Sanitary Commission meets the second Tuesday at 9:00 a.m. in their meeting room located at 107 North Liberty Street, Centreville, Maryland.

In our continuing effort to maintain a safe and dependable water supply it is often necessary to make improvements in your water system. The costs of these improvements, as well as the cost to retain experienced staff, are reflected in the small annual rate increases you may experience every July.

We want our customers to be informed about their water utility. If you have any questions about this report or concerning your water utility, please contact me at the above number.

Very truly yours,

Alan L. Quimby, P.E.
Chief Sanitary Engineer

**2012 Stevensville Water System – Stevensville Area Facilities
REGULATED CONTAMINENTS**

| Contaminant | Units | Level Detected Stevensville | Level Detected Business Park | Level Detected Thompson Creek | MCL | MCLG | Likely Sources |
|-------------------------------|--------|-----------------------------|------------------------------|-------------------------------|---------|--------|-------------------------|
| Gross Alpha ¹ | µrem/y | 328 | Non-Detect | 80 | 15000 | 0 | Natural Deposits |
| Gross Beta ¹ | µrem/y | 576 | 392 | 400 | 4000 | 0 | Natural Deposits |
| Barium | ppb | 160 | 140 | 160 | 2000 | 2000 | Natural Deposits |
| Copper | ppb | 582 | 582 | 582 | AL=1300 | 1300 | Plumbing Corrosion |
| Dalapon | ppb | Non-Detect | Non-Detect | 0.23 | 200 | 200 | Herbicide Runoff |
| Dinoseb | ppb | Non-Detect | Non-Detect | Non-Detect | 7 | 7 | Herbicide Runoff |
| Di(2-ethylhexyl) phthalate | ppb | 1 | Non-Detect | Non-Detect | 6 | 0 | Chemical Factories |
| Nitrate | ppb | Non-Detect | Non-Detect | Non-Detect | 10,000 | 10,000 | Fertilizer Runoff |
| Haloacetic Acids ³ | ppb | 4 | 4 | 4 | 60 | none | Disinfection Byproducts |
| Trihalomethanes ³ | ppb | 1 | 1 | 1 | 100 | none | Disinfection Byproducts |

UNREGULATED (but detected) CONTAMINENTS

| Contaminant | Units | Level Detected Stevensville | Level Detected Business Park | Level Detected Thompson Creek |
|-----------------------------------|--------|-----------------------------|------------------------------|-------------------------------|
| Bromodichloromethane ² | ppb | Non-Detect | 1.5 | 4.7 |
| Chloroform ² | ppb | Non-Detect | 9.1 | 19 |
| Sodium | ppm | 19 | 21 | 44 |
| Sulfate | ppm | 12 | 14 | 6 |
| Radium Combined ¹ | µrem/y | 136 | 72 | Non-Detect |

1. Gross Alpha, Gross Beta, and Radium Combined are a measure of naturally occurring radioactive contaminants.
2. The Md Department of the Environment (MDE) tests for Volatile Organic Compounds (VOC) and Synthetic Organic Compounds (SOC).
3. Test Sample Dates: Lead&Copper **12-31-12**, Nitrate & Nitrite **5-11-12**, Inorganics **5/11/12** (Stv & TC) 6-7-10 (BP), VOC/SOC 6-7-10/3-12-07 (Stv) 5-12-09/6-7-10 (BP) & 3-15-10/1-26-10 (TC), ³Disinfection Byproducts **5-10-12**, Radioactives **4-3-12**.
4. **Bold** indicates new results for this year's report; most contaminants are not required to be tested annually.