



**Queen
Anne's
County**

**DEPARTMENT OF PUBLIC WORKS
SANITARY DISTRICT**

310 Bateau Drive
P.O. Box 10
Stevensville, MD 21666

County Commissioners:

James J. Moran, At Large
Jack N. Wilson, Jr., District 1
Stephen Wilson, District 2
Robert Charles Buckey, District 3
Mark A. Anderson, District 4

Telephone: (410) 643-3535
Fax: (410) 643-7364
www.qac.org

Queen Anne's County
2011 Comprehensive Water and Sewerage Plan
Amendment No.11-12
November 28, 2017

Text Amendment – Town of Queenstown Water System – Section 3.3.3.7 (Page 57)

Insert the below paragraph after existing paragraph 3.

“The Town is proposing the following improvements beginning in 2018. They intend to replace the existing 50,000 gallon water tower located on Wall Street with a new 250,000 gallon tower to be located at an as yet undetermined location. This tower site will also be utilized to drill a new well into the Mattawan aquifer to avoid Arsenic issues encountered in their existing Aquia wells as well as house a new water treatment plant to provide chlorine disinfection for the water provided by the new well. In addition the Town will selectively replace various undersized water mains to accommodate the location of the tower and also bring other sub-standard mains up to industry standards.”

Text Amendment – Water and Sewerage Allocation Policy – Appendix I – (Page 182)

Replace ‘5’ with ‘7’ in Section II.B. 3 & 4, as shown below.

*“3. Residential subdivisions within the S-1 sewerage and/or W-1 water service areas consisting of ~~five (5)~~ **seven (7)** or fewer dwellings.”*

*“4. Minor amendments to major residential subdivisions or other residential developments (minor being defined as ~~5~~ **7** or fewer dwellings).”*

(end of amendment 11-12)

