



NOTES:

1. ALL MOUNTABLE CURB AND GUTTER CONCRETE SHALL BE SHA MIX NO. 3, 3,500 PSI - 28 DAY COMPRESSION STRENGTH.
2. PROVIDE REVERSE LIP GUTTER PAN TO MATCH ADJACENT PAVEMENT WHERE WATER FLOWS AWAY FROM CURB AND WHERE CALLED FOR ON CONSTRUCTION DRAWINGS.
3. CURB HEIGHT SHALL BE ADJUSTED AND SET OUT ON CONSTRUCTION DRAWINGS. MINIMUM HORIZONTAL TRANSITION FROM 6" TO 8" HEIGHT IS 10'.
4. ALL METHODS OF CONSTRUCTION AND LOCATIONS OF CONSTRUCTION OR CONTRACTION JOINTS SHALL BE CONSISTENT WITH THE MDOT/SHA STANDARD SPECIFICATIONS FOR CONSTRUCTION OF MATERIALS.

SHARE1\CAD\ROAD STANDARDS\FINAL\MOUNTED_CURB_DETAIL_103.01.DWG

APPROVED 1-3-03
 DATE

 ACTING
 DIRECTOR, DEPT. OF PUBLIC WORKS

 CHIEF ROADS ENGINEER

SCALE:
 NO SCALE
 REVISIONS:

QUEEN ANNE'S COUNTY
 DEPARTMENT OF PUBLIC WORKS
 MOUNTABLE CURB DETAIL
 STANDARD NO. RD-103.01